



1. ELECTRICAL CONTRACTOR SHALL PROVIDE AND INSTALL BACKBOX AND COVER AT TOP AND BOTTOM OF SURFACE MOUNTED PANELBOARDS. SKIRTS (BACKBOXES AND COVER) SHALL CONCEAL ALL CONDUITS ASSOCIATED WITH PANEL. SKIRT SHALL BE MADE OF 14 GAUGE SHEET METAL AND SHALL EXTEND 3 INCHES BELOW ACCESS FLOOR LINE.
2. PANEL SHALL HAVE HINGED LOCKING DOOR TO CONCEAL CIRCUIT BREAKERS.



PANELS SKIRT AND CAP DETAIL
NOT TO SCALE

**DESIGN SERVICES
PLUS, INC.**
DESIGN, PLANNING
AND DEVELOPMENT

SUITE 700
101 CONVENTION CENTER DR.
LAS VEGAS, NV

www.designservicesplus.com

SUBHAS MAZUMDAR, AIA, NCARB
Design Services Plus, Inc.
101 Convention Center Dr. Suite #700
Las Vegas, NV

TEL: (302) 897 2501



I CERTIFY THAT THESE DOCUMENTS WERE PREPARED
OR APPROVED BY ME, AND THAT I AM A DULY
LICENSED ARCHITECT UNDER THE LAWS OF THE
STATE OF PENNSYLVANIA;

LICENSE NO. 402457, EXPIRING ON 2/17/2018.

Manny Mathai
HEALTHCARE FACILITIES
NURSING HOME (PHASE 2)

ELECTRICAL DETAILS

Project number	SK-2015-006
----------------	-------------

Project number	GR-2015-008
Date	10/14/2015

Drawn by	Author
----------	--------

Checked by	Checker
------------	---------

E-710

Scale $1/8" = 1'-0"$